

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-1633:105 Page 1 of 1

CATEGORY: Leakage Dampers (Smoke)

LISTEE: Perfect Air Control Inc., 896 Rutherford Rd., Marion, NC 28752
Contact: Roger Engelke (828) 652-1424 FAX (828) 652-1729

DESIGN: Models 5600 leakage rated dampers. Refer to listee's data sheet for detailed product description and operational considerations. Models listed below:

<i>Models</i>	<i>Mounting Position</i>	<i>Rating</i>	<i>Width, In.</i>		<i>Height, In.</i>	
			<i>Min</i>	<i>Max</i>	<i>Min</i>	<i>Max</i>
5650FG	V & H	I-550	24	24	18	18
5660FG	V & H	I-550	24	24	24	24

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as leakage rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions.

NOTE: 1. For fire rated classification, refer to CSFM Listing No. 3225-1633:102.
2. Formerly 3230-1518:105

07-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 20, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**